

**The Principal
Maharishi Vidya Mandir Sr. Sec. School
Sector:-F-Extension
Sainik Colony, Tehsil Bahu
District Jammu**

No: JDJF&ES/FPI/1724

Dated: 3/ .03.2021


Sub: Provisional Fire Safety Certificate.

Ref: Your Letter No.MVM/JMU/02/2526 dated: 20.02.2021.

Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed First Aid Fire Extinguishers in their school premises, besides this two underground water storage tanks of about total 30 KL capacity. The school is about 07 Km away from Fire & Emergency Station Gangyal Jammu and is approachable for fire appliances in case of any emergency. Since the school is already functioning as such, the management can proceed ahead for operation provisionally subject to adopt the following fire safety measures in letter and spirit for betterment of the school:-

1. Whenever the second floor of the triple storied block used for school activity, Hose Reel Hoses as per BIS specifications connected with the terrace tank of 5000 Ltrs. capacity should be provided in the triple storied block. The Hose Reel Hose should be kept at such a place where from every nook and corner of each floor of the block are covered easily at the time of any emergency. A Fire Pump of desired capacity should be installed near underground water storage tank with dual electric supply for feeding the terrace tank.
2. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
3. First Aid firefighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/operating of firefighting system installed in the School building. The management shall intimate the office of Deputy Director, Fire & Emergency Services Command Jammu after each quarter that the firefighting equipment installed in the school are functioning.
4. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
5. The corridor of the building shall not be used for any kind of storage.
6. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated withdrawn/cancelled.
7. One window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
8. The management of the school shall be wholly and solely responsible for keeping the firefighting system in working condition 24x7 and safe evacuation of its students during any mishap.
9. At present school is having two blocks, one is double storied and another is triple storied. The second floor of triple storied block is not used by school management at present. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this provisional clearance will be treated withdrawn/cancelled.
10. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
11. The validity of this provisional clearance shall remain in force for one year and same needs to be renewed after checking of firefighting system installed in the school.


Principal

Maharishi Vidya Mandir
Sainik Colony Jammu

Yours Faithfully


Joint Director

Fire & Emergency Services
Jammu Range, Jammu